



SOLID PIPE SLEEVE DETAIL
NTS

NOTES:

1. IF THE CLEARANCE BETWEEN THE MAIN PIPE AND SPOOL PIECE IS GREATER THAN 1/8-INCH AT IT'S NARROWEST POINT, THEN A FULL CIRCLE SPACER OR "DUTCHMAN" MUST BE CUT AND PLACED IN THE GAP BEFORE THE SLEEVE IS USED TO CLOSE THE JOINT.
2. WIDTH OF THE SPACER SHALL BE AS NEEDED TO MEET MAXIMUM CLEARANCES SHOWN IN DETAIL.
3. EACH PIPE SPIGOT SHALL BE MARKED TO INDICATE THE POINT WHERE THE SLEEVE WILL BE PROPERLY CENTERED OVER THE POINT.
4. "FULL-CIRCLE" REPAIR CLAMPS ARE NOT APPROVED FOR JOINING PIPE. SUCH CLAMPS ARE SPECIFICALLY DESIGNED FOR REPAIRS ONLY.
5. IF A STEEL SLEEVE IS USED, PROPERLY COAT BEFORE BACKFILLING.

95% SUBMITTAL

FULTON COUNTY STANDARD DETAIL 130
PIPE JOINING USE OF SOLID SLEEVE

DATE	REVISIONS	DATE	REVISIONS
M/Y	XXX	M/Y	XXX

DGS/DRN/CHKD: XXX
 APPROVED: XXX
 DATE: XX-X-XX



FULTON COUNTY PUBLIC WORKS
 141 PRYOR ST. ATLANTA, GA. 30303
 404-612-7400 FAX: 404-224-0498

DRAWING NO.
130